

FLAMMABILITY TEST SUMMARY

PRODUCT: FRONT RUNNER SERIES

TEST PROCEDURE: ASTM E84-91a "Tunnel Test"

RESULT: Meets NFPA Class A  
Meets UBC Class I

SOUTHWEST RESEARCH INSTITUTE

6220 CULEBRA ROAD • POST OFFICE DRAWER 28510 • SAN ANTONIO, TEXAS, USA 78228-0510 • (210) 684-5111 • TELEX 244898

CHEMISTRY AND CHEMICAL ENGINEERING DIVISION  
DEPARTMENT OF FIRE TECHNOLOGY  
FAX (210) 522-3377

INVESTIGATION OF THE SURFACE BURNING  
CHARACTERISTICS OF A 0.125-IN. THICK  
60% POLYESTER, 40% NYLON NON-BACKED,  
NON-WOVEN FABRIC WALLCOVERING ADHERED  
TO 0.25-IN. THICK GLASS-REINFORCED  
CEMENT BOARD WITH SHURSTIK 111  
FRONT RUNNER

SwRI PROJECT NO. 01-5215-469b

FINAL REPORT

TEST DATE: 9-JUN-1993

Prepared for:


MELDED FABRICS  
1350 N. LAKE SHORE DRIVE  
SUITE 901  
CHICAGO, ILLINOIS 60610

By



Howard W. Stacy  
Manager  
Department of Fire Technology

Approved by:



Alex B. Wenzel  
Director



This report is for the information of the client. It may be used in its entirety for the purpose of securing product acceptance from duly constituted approval authorities. Neither this report nor the name of the Institute shall be used in publicity or advertising.